

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHJECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1130239

Product: Ordinary polychloropren or other equivalent synthetic elastomer sheathed cord and flexible cable

Type: H05RR-F, 05RR-F

Rating: H05RR-F - (2 and 5) x (0,75 - 4) mm²; (3 and 4) x (0,75 - 6) mm²;
05RR-F - 7 x (0,75 - 1,5) mm²; 5 x 6 mm²; 300/500 V

Ordering firm: ProPS, s.r.o.
Nový Svět 89/4, 118 00 Praha 1 - Hradčany, Czech Republic

Manufacturer: ProPS, s.r.o.
U Tržiště 685/1, 594 22 Velké Meziříčí, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 205915-01/01 of: 27.03.2013

A sample of the product was found to be in conformity with:

ČSN EN 50525-2-21:11, ČSN EN 50395:06, ČSN EN 50396:06, ČSN EN 50363-0:06, ČSN EN 50363-1:06,
ČSN EN 50363-2-1:06, ČSN EN 60228:05, ČSN EN 60811-203:13, ČSN EN 60811-501:13, ČSN EN 60811-201:13,
ČSN EN 60811-202:13, ČSN EN 60811-412:13, ČSN EN 60811-401:13, ČSN EN 60811-504:13,
ČSN EN 60811-506:13, ČSN EN 60811-403:13, ČSN EN 60811-507:13, ČSN EN 60811-605:13

The validity of the certificate is limited to: 31.3.2016

9.4.2013

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



205915-01